

Consumer Confidence Report

Annual Drinking Water Quality Report

BONE GAP

IL0470100

Annual Water Quality Report for the period of January 1 to December 31, 2024

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by BONE GAP is Purchased Ground Water

For more information regarding this report contact:

Name Keith Reed

Phone 618-262-4871

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water	Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.
<p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.</p> <p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none">- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.	<p>In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.</p> <p>Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).</p> <p>Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Bone Gap drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk.</p>

people running tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact **Keith Reed** at kreed@ciyoofmcarmel.com. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name	Type of Water	Report Status	Location
CC03 - BONE GAP MASTER METER	FF ILL1850010 CC02 CNCTN	<u>Active</u>	adjacent to the Bone Gap WTP.

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please contact City Hall or call our water operator at **618-262-4871**. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: RURAL WABASH COUNTY WATER DISTRICTThe source water assessment for this system has not yet been completed by the Illinois EPA. EPA is required to complete source water assessments for all public water supplies, when this assessment becomes available we will summarize the results and incorporate the information into this report.

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
 Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: 0 to .623 ppm
 Lead Range: 0 to 24.4 ppb

To obtain a copy of the system's lead tap sampling data: Keith Reed - kreedcityofmtcarmel.com

CIRCLE ONE: Our Community Water Supply has developed a service line material inventory.
 To obtain a copy of the system's service line inventory: kreedcityofmtcarmel.com

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation Likely	Source of Contamination
Copper	2024	1.3	1.3	0.527	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead	2024	0	15	12.2	1	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Water Quality Test Results

Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants									
Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Unlikely Source of Contamination	
Chlorine	2024	1.3	0.5 - 1.5	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.	
Haloacetic Acids (HAA5)	2024	8	8.3 - 8.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.	
Total Trihalomethanes (TTHM)	2024	32	31.8 - 31.8	No goal for the total	80	ppb	N	By-product of drinking water disinfection.	
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Unlikely Source of Contamination	
Arsenic	2024	14.5	8.94 - 14.5	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.	
Barium	2024	0.368	0.284 - 0.368	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposit	
Fluoride	2024	0.18	0.14 - 0.18	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.	
Iron	2024	6.59	4.12 - 6.59		1.0	ppm	N	This contaminant is not currently regulated the USEPA. However, the state regulates. Erosion of natural deposits.	
Manganese	2024	42.6	26.3 - 42.6	150	150	ppb	N	This contaminant is not currently regulated the USEPA. However, the state regulates. Erosion of natural deposits.	
Sodium	2024	72200	37200 - 72200			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.	

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violations Likely Source of Contamination
Combined Radium 226/228	02/27/2023	1.41	0 - 1.41	0	5	pCi/L	N Erosion of natural deposits.
Gross alpha excluding radon and uranium	02/27/2023	2.72	0 - 2.72	0	15	pCi/L	N Erosion of natural deposits.

Violations Table

Chlorine

Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink

Violation Type	Violation Begin	Violation End	Violation Explanation
----------------	-----------------	---------------	-----------------------

MONITORING, ROUTINE (DBP), MAJOR	11/01/2024	11/30/2024	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.
----------------------------------	------------	------------	---

Revised Total Coliform Rule (RTCR)

The Revised Total Coliform Rule (RTCR) seeks to prevent waterborne diseases caused by E. coli. E. coli are bacteria whose presence indicates that the water

Violation Type	Violation Begin	Violation End	Violation Explanation
----------------	-----------------	---------------	-----------------------

MONITORING, ROUTINE, MAJOR (RTCR)	11/01/2024	11/30/2024	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.
-----------------------------------	------------	------------	---

Coliform Monitoring Violation Template

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Bone Gap IL0470100

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During November 1-30 2024 we did not complete all monitoring or testing for total coliform and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for total coliform and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Chlorine	1	0	Nov 2024	Monthly
Total Coliform	1	0	Nov 2024	Monthly

What happened? What is being done?

Regular monthly sampling will resume immediately

For more information, please contact Keith Reed at 618-262-4871 or kreed@cityofmtcarmel.com

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Bone Gap. Water System ID# IL0470100 Date distributed June 2025

Note: daily chlorine tests during this time were in the proper range. -SP